



NATIONAL CERTIFIED TESTING LABORATORIES

5 LEIGH DRIVE
YORK, PA 17406
(717) 846-1200



8350 PARKLINE BLVD
ORLANDO, FL 32809
(407) 240-1356



3310 HILL AVE
EVERETT, WA 98201
(425) 259-6799

SIMULATION TEST REPORT

NCTL-610-22183-1_{E0A0}

REPORT TO:

ClimateGuard Manufacturing
2500 North Pulaski Road
Chicago, IL 60639

SIMULATION DATE: 09/20/19

PRODUCT:

500 Series Single Slider

PRODUCT CPD DESIGNATION:

RSC-A-5

This report is for recertification of an existing product line.



NATIONAL CERTIFIED TESTING LABORATORIES

5 LEIGH DRIVE
YORK, PA 17406
(717) 846-1200

8350 PARKLINE BLVD
ORLANDO, FL 32809
(407) 240-1356

3310 HILL AVE
EVERETT, WA 98201
(425) 259-6799

SIMULATION TEST REPORT

Simulation Standards

ANSI/NFRC 100-2017 "Procedure for Determining Fenestration Product U-factors"

ANSI/NFRC 200-2017 "Procedure for Determining Fenestration Product Solar Heat Gain Coefficients and Visible Transmittance at Normal Incidence"

NFRC 500-2017 "Procedure for Determining Fenestration Product Condensation Resistance Values"

THERM 7 / WINDOW 7 NFRC Simulation Manual (July 2017)
NFRC 2010 Technical Interpretations Manual (November 2017)

Approved Simulation Software

Center of Glass	Window 7.4
2-D Heat Transfer	THERM 7.4
Total Product Calculations	Window 7.4

Note: All dimensions are in the order (Width x Height) unless otherwise noted.

Report Number

NCTL-610-22183-1_{E0A0}

Model/ Series

500 Series Single Slider

Operator Type

Horizontal Slider Type OX (HSOX)

Simulation Size

1500 mm x 1200 mm (59" x 47")

Frame Type

Vinyl (VY)

Nail Fin

Not available

Sash Type

Vinyl with reinforced interlock (VI)

Frame/Sash Material & Finish Rigid vinyl (PVC)

Reinforcement

Mill finish aluminum contour in interior meeting stile

Weather Seal(s)

Right Head
(2) Strips mohair

Right Jamb
(2) Strips mohair

Right Sill
(2) Strips mohair

Meeting Rail
(2) Strips mohair

Left Head
(1) Strip mohair

Left Jamb
(1) Strip mohair

Left Sill
(1) Strip mohair

Edge of Glass

Fixed lite Interior glazed with silicone back bedding on dual leaf, and snap-in dual durometer rigid vinyl glazing bead with dual leaf.
Active lite Exterior glazed with silicone back bedding on dual leaf, and snap-in dual durometer rigid vinyl glazing bead with dual leaf.

Spacer System(s)

Coated steel U-shaped spacer system - dual sealed (CU-D)

Gas Fillings

Argon 95% dual probe per the client (ARG)

Divider(s)

Grid 1
0.1875" x 0.610" painted aluminum rectangle

Divider Notes

Where the space between lite and divider is greater than 3 mm, dividers are not modeled. Solar Heat Gain Coefficient (SHGC) and Visible Light Transmittance (VT) are calculated using default dividers of less than 1" and greater than/ equal to 1".

For U-factor, SHGC, and VT calculations the standard default grid pattern of 12" is used, as established by the Window 7 program.

Notes, Additional Information, Comments, and Assumptions

All simulations use the emissivity from the approved ANSI/NFRC spectral data files with the International Glazing Database (IGDB).

For Solar Heat Gain and Visible Light Transmittance; all frame, divider and glass options are grouped using the best case center of glass/ worst-case frame values from the "U" Factor calculations as required by ANSI/NFRC 200-2017.

A default frame absorptance of 0.30 is assumed for all products except glazing window walls, glazing curtain walls, and slopped glazing wall - all of which will have a frame absorptance of 0.50

This report is the joint property of National Certified Testing Laboratories, Inc. (NCTL) and the client to whom it is issued. Permission to reproduce this report by anyone other than NCTL and the Client must be granted in writing by both of the above parties. This report may not be reproduced except in its entirety

Supporting information including THERM 7 and WINDOW 7 files are being submitted as part of this report. The simulation matrix is being submitted electronically.

Detailed assembly drawings, horizontal and vertical cross-sectional drawings, profile drawings, parts drawings, and a bill of materials as supplied by the client were used as the basis for performing the simulations. Copies are attached to this report. The results were secured by using the designated methods and NFRC approved simulation programs as required by, and in full compliance with, NFRC procedures.

This report does not constitute certification of this product. The results in this report apply only to the sample as shown in the attached drawings, using the components and construction methods described herein. NCTL does not warrant the accuracy of the computer programs used to obtain the results. Client request for work performed by NCTL and its associated documentation constitute approval by client for Inspection Agency (IA) submission.

Ratings values included in this report are for submittals to an NFRC-licensed IA and are not meant to be used directly for labeling purposes. Only those options identified on a valid Certificate of Authorization (CA) by an NFRC accredited Inspection Agency (IA) are to be used for labeling purposes.

The Condensation Resistance results obtained from this procedure are for controlled laboratory conditions and do not include the effects of air movement through the specimen, solar radiation and the thermal bridging that may occur due to the specific design and construction of the fenestration system opening.

Units and rounding is in accordance with NFRC 601, *Units and Measurement Policy* except that all units may be reported in IP as the primary units after conversion and any matrix is reported in IP units only unless requested otherwise by the client.

The manufacturer is capable of producing, in its normal manufacturing process, products in sizes identical to the model sizes listed in the ANSI/NFRC 100 Table 4-3 and have a least deviation of 0 within the tolerances of ANSI/NFRC 100. All simulations are performed in the sizes and configurations listed in ANSI/NFRC 100 Table 4-3 except that a non-standard size may be simulated and identified in the matrix to match the manufacturer's physical test sample. Glass and glazing types, Low-E placement, finishes and other required information is included in the NFRC U-Factor Simulation Summary Report and/ or the NFRC SHGC/ VT Simulation Summary Report included in this document. Additional supporting information and modeling assumptions are included in the individual reports obtained from the approved simulation programs and in the notes following the required summary reports.

National Certified Testing Laboratories

Performed by:



BRYCE PETERS
Simulator/Thermal Tech

Reviewed by:



MARK BENNETT
NFRC Certified Simulator
Simulator-In-Responsible-Charge

Attachments

Glazing Matrix
Appendix A - Revision Summary
Appendix B - Product Drawings

PRODUCT	Product Number	Pane ID #1	Pane ID #2	Pane ID #3	Pane Thickness #1	Pane Thickness #2	Pane Thickness #3	Gap 1	Gap 2	Gap Fill 1	Gap Fill 2	% of Gap Fill 1	% of Gap Fill 2	Emissivity Surface 1	Emissivity Surface 2	Emissivity Surface 3	Emissivity Surface 4	Emissivity Surface 5	Emissivity Surface 6	Tint	Spacer	Grid Type	Grid Size	U-factor	Condensation Resistance	SHGC NO GRID	SHGC GRID<1"	SHGC GRID<=1"	VT NO GRID	VT GRID<1"	VT GRID >=1"
Grids/ No Grids	1	2 mm Clear	2 mm Clear		0.087	0.087		0.678		AIR										CL	CU-D	N,G	0.75	0.47	44		0.62	0.56		0.65	0.58
Grids/ No Grids	2	3 mm Clear	3 mm Clear		0.118	0.118		0.639		AIR										CL	CU-D	N,G	0.75	0.47	43		0.61	0.55		0.64	0.57
No Grids	3	2 mm Clear	2 mm Clear	2 mm Clear	0.087	0.087	0.087	0.290	0.290	AIR	AIR									CL	CU-D	N		0.37	52		0.57			0.60	
Grids/ No Grids	4	2 mm i89	2 mm Clear		0.087	0.087		0.678		ARG		95			0.149					CL	CU-D	N,G	0.75	0.33	55		0.55	0.49		0.64	0.57
Grids/ No Grids	5	3 mm i89	3 mm Clear		0.117	0.118		0.639		ARG		95			0.149					CL	CU-D	N,G	0.75	0.33	55		0.54	0.48		0.63	0.56
No Grids	6	2 mm i89	2 mm Clear	2 mm Clear	0.087	0.087	0.087	0.290	0.290	ARG	ARG	95	95		0.149					CL	CU-D	N		0.29	60		0.50			0.58	
Grids/ No Grids	7	2 mm LoE³ 366	2 mm Clear		0.087	0.087		0.678		ARG		95			0.022					CL	CU-D	N,G	0.75	0.30	58		0.22	0.20		0.51	0.46
Grids/ No Grids	8	3 mm LoE³ 366	3 mm Clear		0.117	0.118		0.639		ARG		95			0.022					CL	CU-D	N,G	0.75	0.29	58		0.22	0.20		0.51	0.45
No Grids	9	2 mm LoE³ 366	2 mm Clear	2 mm Clear	0.087	0.087	0.087	0.290	0.290	ARG	ARG	95	95		0.022					CL	CU-D	N		0.27	61		0.20			0.47	
No Grids	10	2 mm LoE³ 366	2 mm Clear	2 mm LoE³ 366	0.087	0.087	0.087	0.290	0.290	ARG	ARG	95	95		0.022		0.022			CL	CU-D	N		0.23	65		0.19			0.37	
Grids/ No Grids	11	2 mm LoE² 270	2 mm Clear		0.087	0.087		0.678		ARG		95			0.037					CL	CU-D	N,G	0.75	0.30	58		0.29	0.26		0.55	0.49
Grids/ No Grids	12	3 mm LoE² 270	3 mm Clear		0.118	0.118		0.639		ARG		95			0.037					CL	CU-D	N,G	0.75	0.30	57		0.29	0.26		0.55	0.49
No Grids	13	2 mm LoE² 270	2 mm Clear	2 mm Clear	0.087	0.087	0.087	0.290	0.290	ARG	ARG	95	95		0.037					CL	CU-D	N		0.27	61		0.27			0.51	
No Grids	14	2 mm LoE² 270	2 mm Clear	2 mm LoE² 270	0.087	0.087	0.087	0.290	0.290	ARG	ARG	95	95		0.037		0.037			CL	CU-D	N		0.23	65		0.25			0.43	
Grids/ No Grids	15	2 mm LoE² 270	2 mm i89		0.087	0.087		0.678		ARG		95			0.037		0.149			CL	CU-D	N,G	0.75	0.26	46		0.29	0.26		0.54	0.48
Grids/ No Grids	16	3 mm LoE² 270	3 mm i89		0.118	0.117		0.639		ARG		95			0.037		0.149			CL	CU-D	N,G	0.75	0.26	48		0.29	0.26		0.54	0.48
0.1875" x 0.610" Rectangular Painted Aluminium Grids	17	2 mm Clear	2 mm Clear	2 mm Clear	0.087	0.087	0.087	0.290	0.290	AIR	AIR									CL	CU-D	G	0.75	0.38	52			0.51			0.53
0.1875" x 0.610" Rectangular Painted Aluminium Grids	18	2 mm i89	2 mm Clear	2 mm Clear	0.087	0.087	0.087	0.290	0.290	ARG	ARG	95	95		0.149					CL	CU-D	G	0.75	0.30	60			0.45			0.52
0.1875" x 0.610" Rectangular Painted Aluminium Grids	19	2 mm LoE³ 366	2 mm Clear	2 mm Clear	0.087	0.087	0.087	0.290	0.290	ARG	ARG	95	95		0.022					CL	CU-D	G	0.75	0.28	61			0.19			0.42
0.1875" x 0.610" Rectangular Painted Aluminium Grids	20	2 mm LoE³ 366	2 mm Clear	2 mm LoE³ 366	0.087	0.087	0.087	0.290	0.290	ARG	ARG	95	95		0.022		0.022			CL	CU-D	G	0.75	0.23	65			0.17			0.33
0.1875" x 0.610" Rectangular Painted Aluminium Grids	21	2 mm LoE² 270	2 mm Clear	2 mm Clear	0.087	0.087	0.087	0.290	0.290	ARG	ARG	95	95		0.037					CL	CU-D	G	0.75	0.28	61			0.25			0.45
0.1875" x 0.610" Rectangular Painted Aluminium Grids	22	2 mm LoE² 270	2 mm Clear	2 mm LoE² 270	0.087	0.087	0.087	0.290	0.290	ARG	ARG	95	95		0.037		0.037			CL	CU-D	G	0.75	0.24	65			0.23			0.39
Validation, No Grids	0	2 mm LoE² 270	2 mm Clear	2 mm LoE² 270	0.087	0.087	0.087	0.290	0.290	ARG	ARG	95	95		0.037		0.037			CL	CU-D	N		0.23	65		0.25			0.43	