



## NATIONAL CERTIFIED TESTING LABORATORIES

5 LEIGH DRIVE  
YORK, PA 17406  
(717) 846-1200



8350 PARKLINE BLVD  
ORLANDO, FL 32809  
(407) 240-1356



3310 HILL AVE  
EVERETT, WA 98201  
(425) 259-6799

# SIMULATION TEST REPORT

**NCTL-610-23415-1<sub>E0A0</sub>**

**REPORT TO:**

ClimateGuard Manufacturing  
2500 North Pulaski  
Chicago, IL 60639

**SIMULATION DATE:** 08/29/20

**PRODUCT:**

Sliding Glass Door

**PRODUCT CPD DESIGNATION:**

RSC-A-1

This report is for recertification of an existing product line.



## NATIONAL CERTIFIED TESTING LABORATORIES

5 LEIGH DRIVE  
YORK, PA 17406  
(717) 846-1200

8350 PARKLINE BLVD  
ORLANDO, FL 32809  
(407) 240-1356

3310 HILL AVE  
EVERETT, WA 98201  
(425) 259-6799

### SIMULATION TEST REPORT

<b>Simulation Standards</b>	ANSI/NFRC 100-2017 "Procedure for Determining Fenestration Product U-factors"	
	ANSI/NFRC 200-2017 "Procedure for Determining Fenestration Product Solar Heat Gain Coefficients and Visible Transmittance at Normal Incidence"	
	NFRC 500-2017 "Procedure for Determining Fenestration Product Condensation Resistance Values"	
	THERM 7 / WINDOW 7 NFRC Simulation Manual (July 2017)	
	NFRC 2010 Technical Interpretations Manual (November 2017)	
<b>Approved Simulation Software</b>	Center of Glass	Window 7.4
	2-D Heat Transfer	THERM 7.4
	Total Product Calculations	Window 7.4

Note: All dimensions are in the order (Width x Height) unless otherwise noted.

<b>Report Number</b>	NCTL-610-23415-1E0A0
<b>Model/ Series</b>	Sliding Glass Door
<b>Operator Type</b>	Double Door Sliding Glass (DDSG)
<b>Simulation Size</b>	2000 mm x 2000 mm (79" x 79")
<b>Frame Type</b>	Vinyl w/ reinforcement - Interlock (VI)
<b>Nail Fin</b>	Removable and simulated without
<b>Panel Type</b>	Vinyl with reinforcement - Vertical (VV)
<b>Frame/Sash Material &amp; Finish</b>	Rigid vinyl (PVC)
<b>Reinforcement</b>	Galvanized steel in meeting stile and lock stile
<b>Thermal Break(s)</b>	Not applicable
<b>Weather Seal(s)</b>	<u>Right Head</u> (1) Strip mohair
	<u>Right Jamb</u> (1) Strip mohair
	<u>Right Sill</u> (1) Strip mohair
	<u>Meeting Stile</u> Not applicable

	<u>Left Head</u> (1) Strip mohair
	<u>Left Jamb</u> Not applicable
	<u>Left Sill</u> (1) Strip mohair
<b>Edge of Glass</b>	Exterior glazed with silicone back bedding on glazing leg, and snap-in rigid vinyl glazing bead.
<b>Spacer System(s)</b>	Coated steel U-shaped spacer system - dual sealed (CU-D)
<b>Gas Fillings</b>	Argon 90% single probe per the client (ARG)
<b>Divider(s)</b>	<u>Grid 1</u> .1875" x .610" painted aluminum rectangle
<b>Divider Notes</b>	Where the space between lite and divider is greater than 3 mm, dividers are not modeled. Solar Heat Gain Coefficient (SHGC) and Visible Light Transmittance (VT) are calculated using default dividers of less than 1" and greater than/ equal to 1".  For U-factor, SHGC, and VT calculations the standard default grid pattern of 12" is used, as established by the Window 7 program.

---

### ***Notes, Additional Information, Comments, and Assumptions***

---

All simulations use the emissivity from the approved ANSI/NFRC spectral data files with the International Glazing Database (IGDB).

For Solar Heat Gain and Visible Light Transmittance; all frame, divider and glass options are grouped using the best case center of glass/ worst-case frame values from the "U" Factor calculations as required by ANSI/NFRC 200-2017.

A default frame absorptance of 0.30 is assumed for all products except glazing window walls, glazing curtain walls, and slopped glazing wall - all of which will have a frame absorptance of 0.50

This report is the joint property of National Certified Testing Laboratories, Inc. (NCTL) and the client to whom it is issued. Permission to reproduce this report by anyone other than NCTL and the Client must be granted in writing by both of the above parties. This report may not be reproduced except in its entirety

Supporting information including THERM 7 and WINDOW 7 files are being submitted as part of this report. The simulation matrix is being submitted electronically.

Detailed assembly drawings, horizontal and vertical cross-sectional drawings, profile drawings, parts drawings, and a bill of materials as supplied by the client were used as the basis for performing the simulations. Copies are attached to this report. The results were secured by using the designated methods and NFRC approved simulation programs as required by, and in full compliance with, NFRC procedures.

This report does not constitute certification of this product. The results in this report apply only to the sample as shown in the attached drawings, using the components and construction methods described herein. NCTL does not warrant the accuracy of the computer programs used to obtain the results. Client request for



work performed by NCTL and its associated documentation constitute approval by client for Inspection Agency (IA) submission.

Ratings values included in this report are for submittals to an NFRC-licensed IA and are not meant to be used directly for labeling purposes. Only those options identified on a valid Certificate of Authorization (CA) by an NFRC accredited Inspection Agency (IA) are to be used for labeling purposes.

The Condensation Resistance results obtained from this procedure are for controlled laboratory conditions and do not include the effects of air movement through the specimen, solar radiation and the thermal bridging that may occur due to the specific design and construction of the fenestration system opening.

Units and rounding is in accordance with NFRC 601, *Units and Measurement Policy* except that all units may be reported in IP as the primary units after conversion and any matrix is reported in IP units only unless requested otherwise by the client.

The manufacturer is capable of producing, in its normal manufacturing process, products in sizes identical to the model sizes listed in the ANSI/NFRC 100 Table 4-3 and have a least deviation of 0 within the tolerances of ANSI/NFRC 100. All simulations are performed in the sizes and configurations listed in ANSI/NFRC 100 Table 4-3 except that a non-standard size may be simulated and identified in the matrix to match the manufacturer's physical test sample. Glass and glazing types, Low-E placement, finishes and other required information is included in the NFRC U-Factor Simulation Summary Report and/ or the NFRC SHGC/ VT Simulation Summary Report included in this document. Additional supporting information and modeling assumptions are included in the individual reports obtained from the approved simulation programs and in the notes following the required summary reports.

#### National Certified Testing Laboratories

Performed by:



**BRYCE PETERS**  
NFRC Certified Simulator

Reviewed by:

  
DIGITAL SIGNATURE

**MARK BENNETT**  
NFRC Certified Simulator  
Simulator-In-Responsible-Charge

#### Attachments

Glazing Matrix  
Appendix A - Revision Summary  
Appendix B - Product Drawings



**Appendix A****Revision Summary**

<u>Identification</u>	<u>Date</u>	<u>Revision</u>
Original Issue	08/29/20	Report to ClimateGuard Manufacturing and Inspection Agency

Revision Date: 11/14/16