



NATIONAL CERTIFIED TESTING LABORATORIES

5 LEIGH DRIVE
YORK, PA 17406
(717)846-1200

8350 PARKLINE BLVD
ORLANDO, FL 32809
(407)240-1356

3310 HILL AVE
EVERETT, WA 98201
(425)259-4936

SIMULATION TEST REPORT

NCTL-610-20864-1_{E0A0}

REPORT TO:

ClimateGuard Manufacturing
2500 North Pulaski Rd.
Chicago, IL 60639

SIMULATION DATE: 03/23/18

PRODUCT:

4000 Series Vinyl Casement

PRODUCT CPD DESIGNATION:

RSC-A-12

This report is for recertification of an existing product line.



NATIONAL CERTIFIED TESTING LABORATORIES

5 LEIGH DRIVE
YORK, PA 17406
(717)846-1200

8350 PARKLINE BLVD
ORLANDO, FL 32809
(407)240-1356

3310 HILL AVE
EVERETT, WA 98201
(425)259-4936

SIMULATION TEST REPORT

Simulation Standards

ANSI/NFRC 100-2017 "Procedure for Determining Fenestration Product U-factors"

ANSI/NFRC 200-2017 "Procedure for Determining Fenestration Product Solar Heat Gain Coefficients and Visible Transmittance at Normal Incidence"

NFRC 500-2017 "Procedure for Determining Fenestration Product Condensation Resistance Values"

THERM 7 / WINDOW 7 NFRC Simulation Manual (July 2017)
NFRC 2010 Technical Interpretations Manual (November 2017)

Approved Simulation Software

Center of Glass	Window 7.4
2-D Heat Transfer	THERM 7.4
Total Product Calculations	Window 7.4

Note: All dimensions are in the order (Width x Height) unless otherwise noted.

Report Number	NCTL-610-20864-1 _{E0A0}
Model/ Series	4000 Series Vinyl Casement
Operator Type	Casement (CSSV)
Simulation Size	600 mm x 1500 mm (24" x 59")
Frame Type	Vinyl (VY)
Nail Fin	Removable and simulated without
Sash Type	Vinyl (VY)
Frame/Sash Material & Finish	Rigid vinyl (PVC)
Reinforcement	Not applicable
Thermal Break(s)	Not applicable (NA)
Continuous Hardware	Not applicable

Weather Seal(s)	<u>Head</u> (1) Strip mohair; (2) Rigid/Flexible Vinyl (PVC) bulb seals
	<u>Jambs</u> (1) Strip mohair; (2) Rigid/Flexible Vinyl (PVC) bulb seals
	<u>Sill</u> (1) Strip mohair; (2) Rigid/Flexible Vinyl (PVC) bulb seals
Edge of Glass	Interior glazed with a rigid vinyl glazing bead with flexible vinyl fins and a silicone back bedding and dual leaf flexible vinyl gasket.
Spacer System(s)	Coated Steel U-shaped spacer system embedded in sealant - single seal (CU-S)
Gas Fillings	Argon 95% dual probe per the client (ARG)
Divider(s)	<u>Grid 1</u> 0.1875" x 0.610" painted aluminum rectangle
Divider Notes	Where the space between lite and divider is greater than 3 mm, dividers are not modeled. Solar Heat Gain Coefficient (SHGC) and Visible Light Transmittance (VT) are calculated using default dividers of less than 1" and greater than/ equal to 1". For U-factor, SHGC, and VT calculations the standard default grid pattern of 12" is used, as established by the Window 7 program.

Notes, Additional Information, Comments, and Assumptions

All simulations use the emissivity from the approved ANSI/NFRC spectral data files with the International Glazing Database (IGDB).

For Solar Heat Gain and Visible Light Transmittance; all frame, divider and glass options are grouped using the best case center of glass/ worst-case frame values from the "U" Factor calculations as required by ANSI/NFRC 200-2017.

A default frame absorptance of 0.30 is assumed for all products except glazing window walls, glazing curtain walls, and slopped glazing wall - all of which will have a frame absorptance of 0.50

This report is the joint property of National Certified Testing Laboratories, Inc. (NCTL) and the client to whom it is issued. Permission to reproduce this report by anyone other than NCTL and the Client must be granted in writing by both of the above parties. This report may not be reproduced except in its entirety

Supporting information including THERM 7 and WINDOW 7 files are being submitted as part of this report. The simulation matrix is being submitted electronically.

Detailed assembly drawings, horizontal and vertical cross-sectional drawings, profile drawings, parts drawings, and a bill of materials as supplied by the client were used as the basis for performing the simulations. Copies are attached to this report. The results were secured by using the designated methods and NFRC approved simulation programs as required by, and in full compliance with, NFRC procedures.

This report does not constitute certification of this product. The results in this report apply only to the sample as shown in the attached drawings, using the components and construction methods described herein. NCTL does not warrant the accuracy of the computer programs used to obtain the results. Client request for work performed by NCTL and its associated documentation constitute approval by client for Inspection Agency (IA) submission.

Ratings values included in this report are for submittals to an NFRC-licensed IA and are not meant to be used directly for labeling purposes. Only those values identified on a valid Certification Authorization Report (CAR) by an NFRC accredited Inspection Agency (IA) are to be used for labeling purposes.

The Condensation Resistance results obtained from this procedure are for controlled laboratory conditions and do not include the effects of air movement through the specimen, solar radiation and the thermal bridging that may occur due to the specific design and construction of the fenestration system opening.

Units and rounding is in accordance with NFRC 601, *Units and Measurement Policy* except that all units may be reported in IP as the primary units after conversion and any matrix is reported in IP units only unless requested otherwise by the client.

The manufacturer is capable of producing, in its normal manufacturing process, products in sizes identical to the model sizes listed in the ANSI/NFRC 100 Table 4-3 and have a least deviation of 0 within the tolerances of ANSI/NFRC 100. All simulations are performed in the sizes and configurations listed in ANSI/NFRC 100 Table 4-3 except that a non-standard size may be simulated and identified in the matrix to match the manufacturer's physical test sample. Glass and glazing types, Low-E placement, finishes and other required information is included in the NFRC U-Factor Simulation Summary Report and/ or the NFRC SHGC/ VT Simulation Summary Report included in this document. Additional supporting information and modeling assumptions are included in the individual reports obtained from the approved simulation programs and in the notes following the required summary reports.

National Certified Testing Laboratories

Performed by:



KEVIN TRACY
NFRC Certified Simulator

Reviewed by:


DIGITAL SIGNATURE

MARK BENNETT
NFRC Certified Simulator
Simulator-In-Responsible-Charge

Attachments

Glazing Matrix
Appendix A - Revision Summary
Appendix B - Product Drawings

PRODUCT	VT GRID >=1"	VT GRID<1"	VT NO GRID	SHGC GRID>=1"	SHGC GRID<1"	SHGC NO GRID	Condensation Resistance	U-factor	Grid Size	Grid Type	Spacer	Tint	Emissivity Surface 6	Emissivity Surface 5	Emissivity Surface 4	Emissivity Surface 3	Emissivity Surface 2	Emissivity Surface 1	% of Gap Fill 2	% of Gap Fill 1	Gap Fill 2	Gap Fill 1	Gap 2	Gap 1	Pane Thickness #3	Pane Thickness #2	Pane Thickness #1	Pane ID #3	Pane ID #2	Pane ID #1	Product Number	
	0.53	0.48		0.52	0.47	0.52	44	0.40	0.75	N,G	CU-S	CL										AIR		0.678		0.090	0.090	0.090	2 mm Clear	2 mm Clear	2 mm Clear	1
				0.51	0.46		44	0.40	0.75	N,G	CU-S	CL										AIR		0.639		0.118	0.118		3 mm Clear	3 mm Clear	3 mm Clear	2
				0.49			52	0.33		N	CU-S	CL										AIR		0.290	0.090	0.090	2 mm Clear	2 mm Clear	2 mm Clear	2 mm Clear	3	
				0.45	0.41		56	0.29	0.75	N,G	CU-S	CL					0.149				95	ARG		0.678		0.087	0.090		2 mm Clear	2 mm Clear	2 mm i89	4
				0.45	0.41		56	0.29	0.75	N,G	CU-S	CL					0.149				95	ARG		0.639		0.117	0.118		3 mm Clear	3 mm Clear	3 mm i89	5
				0.48			60	0.26		N	CU-S	CL					0.149				95	ARG		0.290	0.090	0.087	0.090	2 mm Clear	2 mm Clear	2 mm i89	6	
				0.18	0.17		59	0.26	0.75	N,G	CU-S	CL					0.022				95	ARG		0.678		0.087	0.090		2 mm Clear	2 mm Clear	2 mm LoE³ 366	7
				0.18	0.17		59	0.26	0.75	N,G	CU-S	CL					0.022				95	ARG		0.639		0.117	0.118		3 mm Clear	3 mm Clear	3 mm LoE³ 366	8
				0.17			62	0.25		N	CU-S	CL					0.022				95	ARG		0.290	0.090	0.087	0.090	2 mm Clear	2 mm Clear	2 mm LoE³ 366	9	
				0.16			66	0.21		N	CU-S	CL		0.022				0.022			95	ARG		0.290	0.087	0.087	0.090	2 mm Clear	2 mm Clear	2 mm LoE³ 366	10	
				0.24	0.22		59	0.27	0.75	N,G	CU-S	CL					0.037				95	ARG		0.678		0.087	0.090		2 mm Clear	2 mm Clear	2 mm LoE² 270	11
				0.24	0.22		58	0.27	0.75	N,G	CU-S	CL					0.037				95	ARG		0.639		0.118	0.118		3 mm Clear	3 mm Clear	3 mm LoE² 270	12
				0.23			61	0.25		N	CU-S	CL					0.037				95	ARG		0.290	0.090	0.087	0.090	2 mm Clear	2 mm Clear	2 mm LoE² 270	13	
				0.24	0.22		46	0.23	0.75	N,G	CU-S	CL					0.037				95	ARG		0.678		0.087	0.087		2 mm i89	2 mm i89	2 mm LoE² 270	14
				0.24	0.22		46	0.23	0.75	N,G	CU-S	CL					0.037				95	ARG		0.639		0.118	0.117		3 mm i89	3 mm i89	3 mm LoE² 270	15
				0.21			66	0.21		N	CU-S	CL		0.037				0.037			95	ARG		0.290	0.087	0.087	0.090	2 mm Clear	2 mm Clear	2 mm LoE² 270	16	
				0.24	0.22		54	0.27	0.75	N,G	CU-S	BZ					0.037				95	ARG		0.658		0.087	0.125		3 mm Bronze	3 mm Bronze	2 mm LoE² 270	17
				0.24	0.22		58	0.27	0.75	N,G	CU-S	BZ					0.037				95	ARG		0.639		0.118	0.125		3 mm Bronze	3 mm Bronze	3 mm LoE² 270	18
				0.22			60	0.25		N	CU-S	BZ					0.037				95	ARG		0.280	0.125	0.087	0.090	2 mm Clear	3 mm Bronze	2 mm Clear	2 mm LoE² 270	19
						52	0.33	0.75	G	CU-S	CL										AIR		0.290	0.090	0.090	0.090	2 mm Clear	2 mm Clear	2 mm Clear	2 mm Clear	20	
						60	0.27	0.75	G	CU-S	CL						0.149				ARG		0.290	0.290	0.090	0.090	2 mm Clear	2 mm Clear	2 mm Clear	2 mm Clear	21	
						62	0.25	0.75	G	CU-S	CL					0.022				95	ARG		0.290	0.290	0.090	0.090	2 mm Clear	2 mm Clear	2 mm Clear	2 mm Clear	22	

PRODUCT	Product Number	Pane ID #1	Pane ID #2	Pane ID #3	Pane Thickness #1	Pane Thickness #2	Pane Thickness #3	Gap 1	Gap 2	Gap Fill 1	Gap Fill 2	% of Gap Fill 1	% of Gap Fill 2	Emissivity Surface 1	Emissivity Surface 2	Emissivity Surface 3	Emissivity Surface 4	Emissivity Surface 5	Emissivity Surface 6	Tint	Spacer	Grid Type	Grid Size	U-factor	Condensation Resistance	SHGC NO GRID	SHGC GRID<1"	SHGC GRID>=1"	VT NO GRID	VT GRID<1"	VT GRID >=1"
0.1875" x 0.610" Rectangle	13	2 mm LoE ³ 366	2 mm Clear	2 mm LoE ³ 366	0.087	0.090	0.087	0.290	0.290	ARG	ARG	95	95	0.022	0.022			0.022		CL	CU-S	G	0.75	0.21	66		0.15				0.27
0.1875" x 0.610" Rectangle	14	2 mm LoE ² 270	2 mm Clear	2 mm Clear	0.087	0.090	0.090	0.290	0.290	ARG	ARG	95	95	0.037	0.037					CL	CU-S	G	0.75	0.25	61		0.21				0.38
0.1875" x 0.610" Rectangle	15	2 mm LoE ² 270	2 mm Clear	2 mm LoE ² 270	0.087	0.090	0.087	0.290	0.290	ARG	ARG	95	95	0.037	0.037			0.037		CL	CU-S	G	0.75	0.22	66		0.19				0.32
0.1875" x 0.610" Rectangle	16	2 mm LoE ² 270	2 mm Clear	3 mm Bronze	0.087	0.090	0.125	0.280	0.280	ARG	ARG	95	95	0.037						BZ	CU-S	G	0.75	0.26	60		0.20				0.28
Validation, No Grids	0	2 mm LoE ² 270	2 mm Clear	2 mm LoE ² 270	0.087	0.090	0.087	0.290	0.290	AIR	AIR			0.037	0.037					CL	CU-S	N		0.25	62		0.21				0.35

Appendix A
Revision Summary

<u>Identification</u>	<u>Date</u>	<u>Revision</u>
Original Issue	03/23/18	Report issued to ClimateGuard Manufacturing and Inspection Agency