



NATIONAL CERTIFIED TESTING LABORATORIES

FIVE LEIGH DRIVE • YORK, PENNSYLVANIA 17406 • TELEPHONE (717) 846-1200
FAX (717) 767-4100
www.nctlinc.com

U-Factor, Solar Heat Gain Coefficient, Visible Transmittance and Condensation Resistance Calculation Report

REPORT NO: NCTL-110-17133-1
SIMULATION DATE: 05/16/14
REPORT DATE: 05/16/14

Client: Remodelers Supply Center
2500 North Pulaski
Chicago, IL 60639

Product Line: Climate Guard Series 4000 Vinyl Fixed

Specification: NFRC 100-2010: "Procedure for Determining Fenestration Product U-Factors".
NFRC 200-2010: "Procedure for Determining Fenestration Product Solar Heat
Gain Coefficients and Visible Transmittance at Normal Incidence".
NFRC 500-2010: "Procedure for Determining Fenestration Product
Condensation Resistance Values".
Therm 6.x / Window 6.x NFRC Simulation Manual (Approved at test date)

**Procedures
and
Compliance:** All U-factor, Solar Heat Gain Coefficients, Visible Transmittance and
Condensation Resistance values were calculated using the following
characteristics: a default value of 0.30 solar absorptance for all products other
than window glazed wall and sloped glazing which have a solar absorptance of
0.50. The best glazing option was used as the configuration for SHGC and VT
specialty products table. NCTL is a NFRC accredited simulation laboratory and
this simulation was conducted in full compliance with NFRC requirements. This
report does not constitute an opinion or endorsement by the laboratory. Ratings
values included in this report are for submittal to an NFRC-licensed IA and are
not meant to be used directly for labeling purposes. Only those values identified
on a valid Certification Authorization Report (CAR) by an NFRC accredited
Inspection Agency (IA) are to be used for labeling purposes. Rounding per NFRC
601-2010: "NFRC Unit and Measurement Policy".

PRODUCT LINE DESCRIPTION

General: The product line modeled is Remodelers Supply Center Series 4000 Vinyl Fixed

Model Size Simulations: 1200mm x 1500mm (47.244" x 59.055")

Weatherseals: Not applicable.

Gas Fillings:

Gas Type	Filling Technique	Percentage
Argon	Double probe	95%

Reinforcement: Not applicable.

Edge – of - Glass – Construction: Exterior and interior vinyl glazing bead with flexible vinyl.

Finish: Vinyl

Frame Description:

Code	Type	Definition
VY	Vinyl	All members are vinyl with no reinforcements

Sash Description:

Code	Type	Definition
VY	Vinyl	All members are vinyl with no reinforcements

Spacer and Sealant:

Code	Type	Definition
CU-D	Coated Steel U-Shaped	Coated Steel (galvanized or tinplated) U-shaped spacer system embedded in sealant

Dividers: Where applicable, dividers were not modeled because the gap between dividers and lites were greater than 3mm. For Solar Heat Gain and Visual Light Transmittance default dividers less than 1” and greater or equal to 1” and default patterns were used for simulations.

Divider Description: .188” x .610” Painted Aluminum Rectangular.

Continuous Hardware Description: Not applicable.

Modeling Assumptions and Comments Deemed Important:

Sealing Rules:

All cavities that are opened to the exterior within a frame section shall be modeled according to ISO 15099, Section 6.7.1, which states that cavities greater than 2mm but equal to or less than 10 mm shall be modeled as “slightly ventilated air cavities”. For physical testing purposes the product is sealed at the inside surface with tape or equivalent to prevent air infiltration. Air cavities created by this sealing technique must be simulated with the standard NFRC “Frame Cavity” material. If cavities on the frame are sealed (covered) to the surround

panel with tape or equivalent, those cavities are also filled with NFRC “Frame Cavity” material within the simulation model. If the frame is not covered or sealed, those areas are left hollow or opened within the simulation model.

Continuous elements:

All elements continuous within the product line are identified from the Bill-of-Materials and detailed drawings via the referenced dimensions and cut lengths as compared to the overall size of the product.

General Notes:

The Condensation Resistance results obtained from this procedure are for controlled laboratory conditions and do not include the effects of air movement through the specimen, solar radiation, and the thermal bridging that may occur due to the specific design and construction of the fenestration system opening.

Miscellaneous assumptions:

1. The screen extrusions were not modeled.
2. All radii are simulated at angles.
3. The modeling was performed in accordance with the manufacturer’s assembly drawing.

Component Area and Frame Heights:

Frame heights, calculated areas, area weighted values for U-factor, SHGC, and VT, and center –of-glazing are located in approved NFRC simulation programs for all individual products.

NCTL Therm Section Filename Methodology

Filename Codes Example: HD-CU-D-F1_003.THM	
HD	Frame Section (Head)
CU-D	Spacer (Intercept)
F1	Frame Description
_003	Glazing ID #3

PRODUCT	Product Number	Pane ID #1	Pane ID #2	Pane ID #3	Pane Thickness #1	Pane Thickness #2	Pane Thickness #3	Gap 1	Gap 2	Gap Fill 1	Gap Fill 2	% of Gap Fill 1	% of Gap Fill 2	Emissivity Surface 1	Emissivity Surface 2	Emissivity Surface 3	Emissivity Surface 4	Emissivity Surface 5	Emissivity Surface 6	Tint	Spacer	Grid Type	Grid Size	U-factor	Condensation Resistance	SHGC NO GRID	SHGC GRID<1"	SHGC GRID>=1"	VT NO GRID	VT GRID<1"	VT GRID >=1"	
	1	2 mm Clear	2 mm Clear		0.089	0.089		0.699		AIR											CL	CU-D	N,G	0.75	0.44	43	0.55	0.60	NA	0.57	0.63	NA
	2	3 mm Clear	3 mm Clear		0.129	0.129		0.639		AIR											CL	CU-D	N,G	0.75	0.43	43	0.53	0.58	NA	0.57	0.62	NA
	3	2 mm Clear	2 mm Clear	2 mm Clear	0.089	0.089	0.089	0.306	0.306	AIR	AIR										CL	CU-D	N		0.34	53	0.50	NA	NA	0.53	NA	NA
	4	2 mm Comfort Select 73	2 mm Clear		0.087	0.089		0.699		ARG		95			0.148						CL	CU-D	N,G	0.75	0.30	55	0.48	0.52	NA	0.54	0.59	NA
	5	3 mm Comfort Select 73	3 mm Clear		0.123	0.129		0.639		ARG		95			0.148						CL	CU-D	N,G	0.75	0.30	55	0.45	0.50	NA	0.52	0.57	NA
	6	2 mm Comfort Select 73	2 mm Clear	2 mm Clear	0.087	0.089	0.089	0.306	0.306	ARG	ARG	95	95		0.148						CL	CU-D	N		0.26	60	0.44	NA	NA	0.49	NA	NA
	7	2 mm LoE3 366	2 mm Clear		0.087	0.089		0.699		ARG		95			0.022						CL	CU-D	N,G	0.75	0.27	58	0.19	0.21	NA	0.45	0.50	NA
	8	3 mm LoE3 366	3 mm Clear		0.117	0.129		0.639		ARG		95			0.022						CL	CU-D	N,G	0.75	0.26	58	0.19	0.21	NA	0.45	0.49	NA
	9	2 mm LoE3 366	2 mm Clear	2 mm Clear	0.087	0.089	0.089	0.306	0.306	ARG	ARG	95	95		0.022						CL	CU-D	N		0.24	62	0.18	NA	NA	0.41	NA	NA
	10	2 mm LoE2 270	2 mm Clear		0.087	0.089		0.699		ARG		95			0.037						CL	CU-D	N,G	0.75	0.27	58	0.26	0.28	NA	0.49	0.54	NA
	11	3 mm LoE2 270	3 mm Clear		0.118	0.129		0.639		ARG		95			0.037						CL	CU-D	N,G	0.75	0.27	57	0.26	0.28	NA	0.49	0.53	NA
	12	2 mm LoE2 270	2 mm Clear	2 mm Clear	0.087	0.089	0.089	0.306	0.306	ARG	ARG	95	95		0.037						CL	CU-D	N		0.24	62	0.24	NA	NA	0.45	NA	NA
	13	2 mm LoE2 270	2 mm Comfort Select 73		0.087	0.087		0.699		ARG		95			0.037	0.148					CL	CU-D	N,G	0.75	0.23	46	0.25	0.27	NA	0.46	0.50	NA
	14	3 mm LoE2 270	3 mm Comfort Select 73		0.118	0.123		0.639		ARG		95			0.037	0.148					CL	CU-D	N,G	0.75	0.23	45	0.25	0.27	NA	0.44	0.49	NA
	15	2 mm LoE2 270	2 mm Clear	2 mm LoE2 270	0.087	0.089	0.087	0.306	0.306	ARG	ARG	95	95		0.037		0.037				CL	CU-D	N		0.20	66	0.22	NA	NA	0.38	NA	NA
	16	2 mm LoE2 272	2 mm Clear		0.087	0.089		0.699		ARG		95			0.042						CL	CU-D	N,G	0.75	0.27	58	0.29	0.32	NA	0.50	0.55	NA
	17	3 mm LoE2 272	3 mm Clear		0.117	0.129		0.639		ARG		95			0.042						CL	CU-D	N,G	0.75	0.27	57	0.29	0.32	NA	0.50	0.55	NA
	18	2 mm LoE2 272	2 mm Clear	2 mm Clear	0.087	0.089	0.089	0.306	0.306	ARG	ARG	95	95		0.042						CL	CU-D	N		0.24	62	0.27	NA	NA	0.46	NA	NA
	19	2 mm LoE2 272	2 mm Comfort Select 73		0.087	0.087		0.699		ARG		95			0.042	0.148					CL	CU-D	N,G	0.75	0.23	46	0.28	0.31	NA	0.47	0.52	NA
	20	3 mm LoE2 272	3 mm Comfort Select 73		0.117	0.123		0.639		ARG		95			0.042	0.148					CL	CU-D	N,G	0.75	0.23	45	0.28	0.30	NA	0.45	0.50	NA

PRODUCT	Product Number	Pane ID #1	Pane ID #2	Pane ID #3	Pane Thickness #1	Pane Thickness #2	Pane Thickness #3	Gap 1	Gap 2	Gap Fill 1	Gap Fill 2	% of Gap Fill 1	% of Gap Fill 2	Emissivity Surface 1	Emissivity Surface 2	Emissivity Surface 3	Emissivity Surface 4	Emissivity Surface 5	Emissivity Surface 6	Tint	Spacer	Grid Type	Grid Size	U-factor	Condensation Resistance	SHGC NO GRID	SHGC GRID<1"	SHGC GRID>=1"	VT NO GRID	VT GRID<1"	VT GRID >=1"		
	21	2 mm LoE ² 272	2 mm Clear	2 mm LoE ² 272	0.087	0.089	0.087	0.306	0.306	ARG	ARG	95	95		0.042						CL	CU-D	N		0.20	66		0.25	NA	NA	0.40	NA	NA
Rectangular Grid	22	2 mm Clear	2 mm Clear	2 mm Clear	0.089	0.089	0.089	0.306	0.306	AIR	AIR										CL	CU-D	G	0.75	0.34	53		NA	0.54	NA	NA	0.58	NA
Rectangular Grid	23	2 mm Comfort Select 73	2 mm Clear	2 mm Clear	0.087	0.089	0.089	0.306	0.306	ARG	ARG	95	95		0.148						CL	CU-D	G	0.75	0.26	60		NA	0.48	NA	NA	0.54	NA
Rectangular Grid	24	2 mm LoE ³ 366	2 mm Clear	2 mm Clear	0.087	0.089	0.089	0.306	0.306	ARG	ARG	95	95		0.022						CL	CU-D	G	0.75	0.24	62		NA	0.20	NA	NA	0.46	NA
Rectangular Grid	25	2 mm LoE ² 270	2 mm Clear	2 mm Clear	0.087	0.089	0.089	0.306	0.306	ARG	ARG	95	95		0.037						CL	CU-D	G	0.75	0.24	62		NA	0.27	NA	NA	0.49	NA
Rectangular Grid	26	2 mm LoE ² 270	2 mm Clear	2 mm LoE ² 270	0.087	0.089	0.087	0.306	0.306	ARG	ARG	95	95		0.037				0.037		CL	CU-D	G	0.75	0.21	66		NA	0.24	NA	NA	0.42	NA
Rectangular Grid	27	2 mm LoE ² 272	2 mm Clear	2 mm Clear	0.087	0.089	0.089	0.306	0.306	ARG	ARG	95	95		0.042						CL	CU-D	G	0.75	0.24	62		NA	0.30	NA	NA	0.51	NA
Rectangular Grid	28	2 mm LoE ² 272	2 mm Clear	2 mm LoE ² 272	0.087	0.089	0.087	0.306	0.306	ARG	ARG	95	95		0.042				0.042		CL	CU-D	G	0.75	0.21	66		NA	0.28	NA	NA	0.44	NA

A baseline product test in accordance with the "NFRC 102: Test Procedure for Measuring the Steady-State Thermal Transmittance of Fenestration Systems" is required in order to validate the "Model Size Matrix of U-Values" as previously indicated. Per Section 1.4.3 of NFRC 100-2010, "the baseline product is the individual product selected for validation testing". **The individual product selected as the baseline product shall be the lowest simulated individual product or an individual product having a simulated U-factor within 0.60 W/ (m²*K) (0.10 BTU/HR/ft²/°F) or 20% of the listed lowest simulated U-factor.**

Note:

1. For lowest U-factor listings where multiple individual products are shown, validation testing can be conducted on any within 20% of the lowest simulated u-factor.
2. Actual simulated individual products are required for product line validation testing.

For the purposes of validation testing, production line units and sizes shall be used to represent the baseline product. Per the client, the model size is manufactured as part of their product line; therefore the previously listed model size can be used for baseline product validation testing.

Copies of this report and the detailed product drawings will be retained by NCTL for a period of four (4) years. This report may not be reproduced, except in full, without the approval of NCTL. The results only to the fenestration product simulated. The attached diskette(s) contain(s) all required NFRC data and software files.

NATIONAL CERTIFIED TESTING LABORATORIES

Performed by:


DIGITAL SIGNATURE

CHRISTOPHER PONDOLFINO
Simulator

Reviewed by:


DIGITAL SIGNATURE

STEVEN H. COBLE
NFRC Accredited Simulator
Simulator-In-Responsible-Charge

Attachments