

NATIONAL CERTIFIED TESTING LABORATORIES

FIVE LEIGH DRIVE • YORK, PENNSYLVANIA 17406 •

TELEPHONE (717) 846-1200 FAX (717) 767-4100 www.nctlinc.com

U-Factor, Solar Heat Gain Coefficient, Visible Transmittance and **Condensation Resistance Calculation Report**

REPORT NO: SIMULATION DATE: REPORT DATE:

NCTL-110-17476-1 2/23/15 2/23/15

Client: Remodelers Supply Center 2500 North Pulaski Chicago, IL 60639

Product Line: Remodelers Supply Center ClimateGuard 2000 Vinyl Double Slider

- Specification: NFRC 100-2014: "Procedure for Determining Fenestration Product U-Factors". NFRC 200-2014: "Procedure for Determining Fenestration Product Solar Heat Gain Coefficients and Visible Transmittance at Normal Incidence". NFRC 500-2014: "Procedure for Determining Fenestration Product Condensation Resistance Values". Therm 6.x / Window 6.x NFRC Simulation Manual (Approved at test date)
- **Procedures and** All U-factor, Solar Heat Gain Coefficients, Visible Transmittance and Condensation Compliance: Resistance values were calculated using the following characteristics: a default value of 0.30 solar absorptance for all products other than window glazed wall and sloped glazing which have a solar absorptance of 0.50. The best glazing option was used as the configuration for SHGC and VT specialty products table. NCTL is a NFRC accredited simulation laboratory and this simulation was conducted in full compliance with NFRC requirements. This report does not constitute an opinion or endorsement by the laboratory. Ratings values included in this report are for submittal to an NFRC-licensed IA and are not meant to be used directly for labeling purposes. Only those values identified on a valid Certification Authorization Report (CAR) by an NFRC accredited Inspection Agency (IA) are to be used for labeling purposes. Rounding per NFRC 601-2014: "NFRC Unit and Measurement Policy". The values included in this report are not considered in compliance with NFRC 100, NFRC 200, and/or NFRC 500 unless the associated validation test requirements have been satisfied, as applicable. Component values included in this report are for submittals to an NFRC-licensed IA and are not meant to be used directly for labeling purposes. Only those values approved and identified on a valid CMA Label Certificate are to be used for labeling purposes. The component(s) values included in this report are not considered in compliance with NFRC 100 or NFRC 200 unless the associated validation test requirements have been satisfied, as applicable.

PRODUCT LINE DESCRIPTION

General: The product line modeled is Remodelers Supply Center ClimateGuard 2000 Vinyl Double Slider

Model Size Simulations: 1500mm x 1200mm (59.055" x 47.244")

Weatherseals:

Location	Weather Seal Description
Left Head	(3) Strips of Mohair
Left Jamb	(3) Strips of Mohair
Left Sill	(3) Strips of Mohair
Meeting Rail	(3) Strips of Mohair
Right Head	(3) Strips of Mohair
Right Jamb	(3) Strips of Mohair
Right Sill	(3) Strips of Mohair

Gas Fillings:

Gas Type	Filling Technique	Percentage
Argon	Double probe	95%
68% Argon / 22% Krypton	Double probe	90%

Reinforcement: Not applicable

Edge – of - Glass – Construction: Exterior silicone back bedding with one strip of flexible vinyl and Interior Vinyl Glazing Bead with flexible vinyl tips.

Finish: Vinyl

Frame Description:

Code	Туре	Definition
VF	Vinyl w/ foam-filled insulation	Extrusions are filled with a foam-type insulating material
VY	Vinyl	All members are vinyl with no reinforcements

Sash Description:

Code	Туре	Definition
VF	Vinyl w/ foam-filled insulation	Extrusions are filled with a foam-type insulating material
VY	Vinyl	All members are vinyl with no reinforcements

Spacer and Sealant:

Code	Туре	Definition
CU-S	Coated Steel U-Shaped	Coated Steel (galvanized or tinplated) U-shaped spacer system embedded in sealant

Dividers: Where applicable, dividers were not modeled because the gap between dividers and lites were greater than 3mm. For Solar Heat Gain and Visual Light Transmittance default dividers less than 1" and greater or equal to 1" and default patterns were used for simulations.

Divider Description: 0.1875" x 0.610" Painted Aluminum Rectangular.

Foam fillings: Individual products contain foam filled channels (hollows) in the following extrusions:

Number of Channels	Extrusion Location	Dwg. No.					
Three	Bottom of Frame -All Sections	Assembly Dwg.					
One	Sash	Assembly Dwg.					

Continuous Hardware Description: Not applicable

Modeling Assumptions and Comments Deemed Important:

Sealing Rules:

All cavities that are opened to the exterior within a frame section shall be modeled according to ISO 15099, Section 6.7.1, which states that cavities greater than 2mm but equal to or less than 10 mm shall be modeled as "slightly ventilated air cavities". For physical testing purposes the product is sealed at the inside surface with tape or equivalent to prevent air infiltration. Air cavities created by this sealing technique must be simulated with the standard NFRC "Frame Cavity" material. If cavities on the frame are sealed (covered) to the surround panel with tape or equivalent, those cavities are also filled with NFRC "Frame Cavity" material within the simulation model. If the frame is not covered or sealed, those areas are left hollow or opened within the simulation model.

Continuous elements:

All elements continuous within the product line are identified from the Bill-of-Materials and detailed drawings via the referenced dimensions and cut lengths as compared to the overall size of the product.

General Notes:

The Condensation Resistance results obtained from this procedure are for controlled laboratory conditions and do not include the effects of air movement through the specimen, solar radiation, and the thermal bridging that may occur due to the specific design and construction of the fenestration system opening.

Miscellaneous assumptions:

- 1. The screen extrusions were not modeled.
- 2. All radii are simulated at angles.
- 3. The modeling was performed in accordance with the manufacturer's assembly drawing.

Component Area and Frame Heights:

Frame heights, calculated areas, area weighted values for U-factor, SHGC, and VT, and center –ofglazing are located in approved NFRC simulation programs for all individual products.

Filename	Codes Example: HD-CU-D- F1_003.THM
HD	Frame Section (Head)
CU-D	Spacer (Intercept)
F1	Frame Description
_003	Glazing ID #3

NCTL Therm Section Filename Methodology

PRODUCT	Product Number	Pane ID #1	Pane ID #2	Pane ID #3	Pane Thickness #1	Pane Thickness #2	Pane Thickness #3	Gap 1	Gap 2	Gap Fill 1	Gap Fill 2	% of Gap Fill 1	% of Gap Fill 2	Emissivity Surface 1	Emissivity Surface 2	Emissivity Surface 3	Emissivity Surface 4	Emissivity Surface 5	Emissivity Surface 6			Grid Type	Grid Size	U-factor	Condensation Resistance	SHGC NO GRID	SHGC GRID<1"	SHGC GRID>=1"			VT GRID >=1"
	1	2 mm Clear	2 mm Clear		0.089	0.089		0.678		AIR									(CL C	U-S	N,G	0.75	0.46	42	0.59	0.53	NA	0.62	0.55	NA
	2	3 mm Clear	3 mm Clear		0.129	0.129		0.639		AIR									(CL C	U-S	N,G	0.75	0.46	42	0.58	0.51	NA	0.61	0.55	NA
	3	2 mm Clear	2 mm Clear	2 mm Clear	0.089	0.089	0 089	0.290	0.290	AIR	AIR			-					-	U L	U-S	N		0.37	50	0.54	NA	NA	0.57	NA	NA
	5	2 mill Clear	2 min cicar	2 min Clear			0.007				AIK																				
	4	2 mm Comfort Select 73	2 mm Clear		0.087	0.089		0.678		ARG		95			0.148				(CL C	U-S	N,G	0.75	0.33	52	0.52	0.46	NA	0.58	0.52	NA
	5	3 mm Comfort Select 73	3 mm Clear		0.123	0.129		0.639		ARG		95			0.148				(CL C	U-S	N,G	0.75	0.33	52	0.49	0.44	NA	0.56	0.50	NA
	6	2 mm Comfort Select 73	2 mm Clear	2 mm Clear	0.007	0.080	0.000	0.200	0.290	ADC	ADC	95	95		0.148				(LC	TIC	N		0.29	57	0.47	NIA	NIA	0.53	NA	NA
	0	2 min connort select 75	2 min clear	2 IIIII Clear	0.087	0.089	0.089	0.290	0.290	AKU	AKU	95	95		0.148						.0-3	19		0.29	57	0.47	INA	INA	0.55	INA	
	7	2 mm LoE ³ 366	2 mm Clear		0.087	0.089		0.678		ARG		95			0.022				(CL C	U-S	N,G	0.75	0.29	55	0.21	0.19	NA	0.49	0.44	NA
	8	2 mm LoE ³ 366	3 mm Clear		0.117	0.129		0.639		ARG		95			0.022				(L C	U-S	N,G	0.75	0.29	54	0.21	0.19	NA	0.49	0.43	NA
		A 1 17 A 66			0.007	0.000	0.000	0.000	0.000		100	0.5	0.5		0.000					77 6				0.07	50	0.00			0.45		
	9	2 mm LoE ³ 366	2 mm Clear	2 mm Clear	0.087	0.089	0.089	0.290	0.290	ARG	ARG	95	95		0.022				(LC	U-S	N		0.27	58	0.20	NA	NA	0.45	NA	NA
	10	2 mm LoE ² 270	2 mm Clear		0.087	0.089		0.678		ARG		95			0.037				(CL C	U-S	N,G	0.75	0.30	54	0.28	0.25	NA	0.53	0.47	NA
	11	3 mm LoE ² 270	3 mm Clear		0.118	0.129		0.639		ARG		95			0.037				0	L C	U-S	NG	0.75	0.30	54	0.28	0.25	NA	0.53	0.47	NA
																							0.70								
	12	2 mm LoE ² 270	2 mm Clear	2 mm Clear	0.087	0.089	0.089	0.290	0.290	ARG	ARG	95	95	_	0.037				(CL C	U-S	N		0.27	58	0.26	NA	NA	0.49	NA	NA
	13	2 mm LoE ² 270	2 mm Comfort Select 73		0.087	0.087		0.678		ARG		95			0.037		0.148		(CL C	U-S	N,G	0.75	0.26	44	0.27	0.24	NA	0.50	0.44	NA
	14	2 L . F2 270	2 mm Camfart Calast 72		0.110	0.122		0.620		ADC		05			0.027		0.149			TI C	TLC.	NC	0.75	0.26	42	0.26	0.24	NIA	0.49	0.42	NIA
	14	3 mm LoE ² 270	3 mm Comfort Select 73		0.118	0.123		0.639		ARG		95			0.037		0.148			LC	.0-5	N,G	0.75	0.26	43	0.26	0.24	NA	0.48	0.43	NA
	15	2 mm LoE ² 270	2 mm Clear	2 mm LoE ² 270	0.087	0.089	0.087	0.290	0.290	ARG	ARG	95	95		0.037			0.037	(CL C	U-S	Ν		0.23	61	0.24	NA	NA	0.42	NA	NA
	16	2 mm LoE ² 272	2 mm Clear		0.087	0.089		0.678		ARG		95		-	0.042				0	L C	U-S	N,G	0.75	0.30	54	0.32	0.28	NA	0.55	0.49	NA
			A A																											0.40	
	17	3 mm LoE ² 272	3 mm Clear		0.117	0.129		0.639		ARG		95			0.042				(LC	U-S	N,G	0.75	0.30	54	0.31	0.28	NA	0.54	0.48	NA
	18	2 mm LoE ² 272	2 mm Clear	2 mm Clear	0.087	0.089	0.089	0.290	0.290	ARG	ARG	95	95		0.042				(CL C	U-S	Ν		0.28	58	0.30	NA	NA	0.50	NA	NA
	19	2 mm LoE ² 272	2 mm Comfort Select 73		0.087	0.087		0.678		ARG		95		+	0.042		0.148			T. C	U-S	NG	0.75	0.26	43	0.30	0.27	NA	0.51	0.46	NA
					5.007	5.007											0.140														
	20	3 mm LoE ² 272	3 mm Comfort Select 73		0.117	0.123		0.639		ARG		95	<u> </u>		0.042		0.148		0	CL C	U-S	N,G	0.75	0.26	43	0.30	0.27	NA	0.49	0.44	NA
	21	2 mm LoE ² 272	2 mm Clear	2 mm LoE ² 272	0.087	0.089	0.087	0.290	0.290	ARG	ARG	95	95		0.042			0.042	(CL C	U-S	Ν		0.24	61	0.27	NA	NA	0.44	NA	NA
	22	2 mm LoE ² 270	2 mm Clear	2 mm LoE ² 270	0.007	0.080	0.007	0.200	0.200	AR3	402	68/22	60/00		0.037			0.037		LC	TI C	N		0.22	62	0.24	NLA	NIA	0.42	NA	NA
	22	2 mm LOE* 2/0	2 mm Clear	2 mm Loe* 270	0.087	0.089	0.08/	0.290	0.290	AK3	AK3	08/22	08/22	4	0.037			0.037			.0-3	IN		0.22	02	0.24	INA	INA	0.42	INA	INA
	23	2 mm LoE ² 272	2 mm Clear	2 mm LoE ² 272	0.087	0.089	0.087	0.290	0.290	AR3	AR3	68/22	68/22	2	0.042			0.042	(CL C	U-S	Ν		0.23	62	0.27	NA	NA	0.44	NA	NA

PRODUCT	Product Number	Pane ID #1	Pane ID #2	Pane ID #3	Pane Thickness #1	Pane Thickness #2	Pane Thickness #3	Gap 1	Gap 2	Gap Fill 1	Gap Fill 2	% of Gap Fill 1	% of Gap Fill 2	Emissivity Surface 1	Emissivity Surface 2	Emissivity Surface 3	Emissivity Surface 4	Emissivity Surface 5	Emissivity Surface 6	, Tint	Spacer	Grid Type	Grid Size	U-factor	Condensation Resistance	SHGC NO GRID	SHGC GRID<1"	SHUC UKID>=1	VT NO GRID	VT GRID<1"	VT GRID >=1"
Destan sular Crid	24	2	2	2	0.090	0.090	0.000	0.200	0.200	AID	AIR									TC	TIC	C	0.75	0.27	50	N		40 N	A N	105	1 1 4
Rectangular Grid	24	2 mm Clear	2 mm Clear	2 mm Clear	0.089	0.089	0.089	0.290	0.290	AIR	AIK									CL C	.U-S	G	0.75	0.37	50	IN.	A 0.4	48 N	A N	A 0.5	INA
Rectangular Grid	25	2 mm Comfort Select 73	2 mm Clear	2 mm Clear	0.087	0.089	0.089	0.290	0.290	ARG	ARG	95	95		0.148				(CL C	U-S	G	0.75	0.30	57	N	A 0.4	42 N	A N	A 0.4	8 NA
Rectangular Grid	26	2 mm LoE ³ 366	2 mm Clear	2 mm Clear	0.087	0.089	0.089	0.290	0.290	ARG	ARG	95	95		0.022				(CL C	U-S	G	0.75	0.28	58	N	A 0.1	18 N	A NA	A 0.4	0 NA
Rectangular Grid	27	2 mm LoE ² 270	2 mm Clear	2 mm Clear	0.087	0.089	0.089	0 290	0.290	ARG	ARG	95	95		0.037					LC	U-S	G	0.75	0.28	58	N	A 0 2	24 N	AN	A 0.4	3 NA
Treetungului Oriu	2.	2 min Lot 270	2 1111 0.00	2 milliolotui	0.007	0.007	0.007	0.270	0.270		· mto	,,,	10		0.007							0	0.70	0.20	50	1.					
Rectangular Grid	28	2 mm LoE ² 270	2 mm Clear	2 mm LoE ² 270	0.087	0.089	0.087	0.290	0.290	ARG	ARG	95	95		0.037			0.037	(CL C	U-S	G	0.75	0.24	61	N	A 0.2	22 N	A NA	A 0.3	7 NA
Rectangular Grid	29	2 mm LoE ² 272	2 mm Clear	2 mm Clear	0.087	0.080	0.080	0.200	0.290	APC	APG	95	95		0.042		-			T C	TI S	G	0.75	0.28	59	N	1 0 2	27 N	A N	A 0.4	4 NA
Rectaigulai Oriu	29	2 IIIII LOE- 272	2 min Clear	2 min Clear	0.087	0.089	0.089	0.290	0.290	AKU	AKU	95	95		0.042					JL C	.0-5	U	0.75	0.20	58	192	A 0.2	27 19	A 192	1 0.4	+ 19/4
Rectangular Grid	30	2 mm LoE ² 272	2 mm Clear	2 mm LoE ² 272	0.087	0.089	0.087	0.290	0.290	ARG	ARG	95	95		0.042			0.042	(CL C	U-S	G	0.75	0.24	61	N	A 0.2	24 N	A NA	A 0.3	9 NA
												-0.00	-0.4									~									
Rectangular Grid	31	2 mm LoE ² 270	2 mm Clear	2 mm LoE ² 270	0.087	0.089	0.087	0.290	0.290	AR3	AR3	68/22	68/22		0.037			0.037	(LC	U-S	G	0.75	0.25	62	N	A 0.2	22 N	A NA	A 0.3	/ NA
Rectangular Grid	32	2 mm LoE ² 272	2 mm Clear	2 mm LoE ² 272	0.087	0.089	0.087	0.290	0.290	AR3	AR3	68/22	68/22		0.042			0.042	(L C	U-S	G	0.75	0.24	62	N	A 0.2	24 N	A N	A 0.3	9 NA
Foam Filled,	33	2 mm LoE ² 270	2 mm Clear	2 mm LoE ² 270	0.087	0.089	0.087	0.290	0.290	AR3	AR3	68/22	68/22		0.037			0.037	(CL C	U-S	N		0.22	62	0.2	24 N.	A N	A 0.4	12 NA	A NA
Foam Filled,	34	2 mm LoE ² 272	2 mm Clear	2 mm LoE ² 272	0.087	0.089	0.087	0.290	0.290	AR3	AR3	68/22	68/22		0.042			0.042		T C	U-S	N		0.22	62	0.2	7 N	A N	A 0.4	14 NA	A NA
roun rinou,	54	2 mm EoE 272	2 1111 Clou	2 LOL 272	5.007	0.007	0.007	5.270	5.270			50/22	50/22		0.042			5.042	t t		55	11		5.22	02	0.2					
Foam Filled, Rectangular Grid	35	2 mm LoE ² 270	2 mm Clear	2 mm LoE ² 270	0.087	0.089	0.087	0.290	0.290	AR3	AR3	68/22	68/22		0.037			0.037	(CL C	U-S	G	0.75	0.24	62	N	A 0.2	22 N	A NA	A 0.3	7 NA
From Ethel Destance 1 - C - 1	26	2 mm L - E2 272	2	2 L . E2 070	0.007	0.000	0.007	0.200	0.200	4.0.2	4.0.2	(9/22	69/00	$\left \right $	0.042			0.042		T	U-S	C	0.75	0.22	0	N.		14 21	A 37	1 0 2	ONA
Foam Filled, Rectangular Grid	30	2 mm LoE ² 272	2 mm Clear	2 mm LoE ² 272	0.087	0.089	0.087	0.290	0.290	AK3	AK3	68/22	08/22	4	0.042	1		0.042		лIС	.U-S	G	0.75	0.23	62	IN.	A 0.2	24 N	A N	A 0.3	9 NA

A baseline product test in accordance with the "NFRC 102: Test Procedure for Measuring the Steady-State Thermal Transmittance of Fenestration Systems" is required in order to validate the "Model Size Matrix of U-Values" as previously indicated. Per Section 1.4.3 of NFRC 100-2014, "the baseline product is the individual product selected for validation testing". The individual product selected as the baseline product shall be the lowest simulated individual product or an individual product having a simulated U-factor within 0.60 W/ (m²*K) (0.10 BTU/HR/ft²/°F) or 20% of the listed lowest simulated U-factor.

Note:

- 1. For lowest U-factor listings where multiple individual products are shown, validation testing can be conducted on any within 20% of the lowest simulated u-factor.
- 2. Actual simulated individual products are required for product line validation testing.

For the purposes of validation testing, production line units and sizes shall be used to represent the baseline product. Per the client, the model size is manufactured as part of their product line; therefore the previously listed model size can be used for baseline product validation testing.

For the purposes of validation testing, production line units and sizes shall be used to represent the baseline products. Representative sizes are therefore defined as the production sizes with the least deviation (D) from the model sizes, calculated per NFRC 100. The previously listed model sizes shall be used for baseline product validation testing.

Copies of this report and the detailed product drawings will be retained by NCTL for a period of four (4) years. This report may not be reproduced, except in full, without the approval of NCTL. The results only to the fenestration product simulated. The attached diskette(s) contain(s) all required NFRC data and software files.

NATIONAL CERTIFIED TESTING LABORATORIES

Performed by:

SIGNATURE

Simulator

Attachments

Reviewed by:

DIGITAL SIGNATURE MARK BENNETT NFRC Accredited Simulator Simulator–In–Responsible–Charge